Sub





Attestation of Conformity

No. N8A 099333 0072 Rev. 00

Holder of Certificate:

LONGi Green Energy Technology Co., Ltd.

No. 388, Middle Hangtian Road

Chang'an District

710100 Xi'an City, Shaanxi

PEOPLE'S REPUBLIC OF CHINA

Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance.

It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

704061802022-06

Date,

2020-03-19

(Zhulin Zhang)

gate of

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 099333 0072 Rev. 00

Model(s):

LR6-72-xxxM, (xxx=335 to 360 in step of 5) LR6-60-xxxM, (xxx=280 to 300 in step of 5) LR6-72PE-xxxM, (xxx=340 to 380 in step of 5) LR6-60PE-xxxM, (xxx=285 to 315 in step of 5) LR6-72BK-xxxM, (xxx=335 to 360 in step of 5) LR6-60BK-xxxM, (xxx=280 to 300 in step of 5) LR6-72PB-xxxM, (xxx=340 to 380 in step of 5) LR6-60PB-xxxM, (xxx=285 to 315 in step of 5) LR6-72HPB-xxxM, (xxx=360 to 385 in step of 5) LR6-60HPB-xxxM, (xxx=300 to 320 in step of 5) LR4-72HPB-xxxM, (xxx=405 to 425 in step of 5) LR4-60HPB-xxxM, (xxx=335 to 365 in step of 5) LR6-60HIB-xxxM, (xxx=300 to 320 in step of 5) LR4-60HIB-xxxM, (xxx=335 to 365 in step of 5) LR4-60ZPB-xxxM, (xxx=340 to 360 in step of 5) LR4-60ZIB-xxxM, (xxx=340 to 360 in step of 5) LR4-60HP-xxxM, (xxx=350 to 375 in step of 5) xxx is standing for rated output power at STC

Parameters:

Fire Safety Class:

Class C according to UL790.

Safety Class:

Class II

Max. System Voltage:

1000V DC

Test Laboratory:

Yangzhou Opto-Electrical

Products Testing Institute.

No.10 West Kaifa Road, Yangzhou

225009 Jiangsu, P.R.China

Construction:

Framed, with Junction box,

cable and connector.

Tested according to: EN IEC 61730-1:2018

EN IEC 61730-1:2018/AC:2018-06

EN IEC 61730-2:2018

EN IEC 61730-2:2018/AC:2018-06

Ons

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

