

**Technical Report No.: 64.290.23.30804.01**

**Date: 2023-06-25**

**Client:** Shenzhen Kstar New Energy Company Limited  
The 9th Floor, R&D Building, Kstar Industrial Park, Guangming Hi-tech Industrial Zone, 518107 Shenzhen, Guangdong Province, PEOPLE'S REPUBLIC OF CHINA

**Manufacturer:** Same as Client

**Factory:** Shenzhen KSTAR Science & Technology Co., Ltd. Guangming Branch  
Kstar High Tech Park, Guangming High Technology Town, Gongming Street, Baoan District, Shenzhen City, Guangdong Province, PEOPLE'S REPUBLIC OF CHINA

**Test object:** Product: Hybrid inverter  
Model: KAC50DP

**Test specification:** C10/11:2021


**Purpose of examination:** • Testing and evaluation visual according to the test specification

**Test result:** The test results show that the presented product is in compliance with the above listed test specifications.

*Any use for advertising purposes must be granted in writing. This technical report may only be quoted in full. This report is the result of a single examination of the object in question. It does not imply a general statement regarding the quality of products from regular production. For further details please see testing and certification regulation, chapter A-3.4.*

### 1. Description of the test object


#### 1.1 Picture(s)



## 1.2 Function

Manufacturer's specification for intended use:

- (1) The unit is non-isolated (transformerless) Hybrid Inverter with a maximum power  $\leq 250$  kVA connected to public grid, for indoor and outdoor use, and defined as type A generator according to Regulation (EU) 2016/631 (NC RfG) and C10/11:2021.
- (2) Low voltage electrical installations shall comply with national and local regulation. Only qualified electricians are allowed to install and maintain the converter.
- (3) In order to protect the inverter, user and installer, external DC and AC circuit breaker shall be equipped for all source port (battery, AC grid) at the end-use application.
- (4) The unit has below reactive power control modes, shall comply with national and local regulation:
  - 1) Q setpoint mode
  - 2) Q(U) mode
  - 3) Cos  $\varphi$  setpoint mode
  - 4) Cos  $\varphi$  (P)
- (5) The inverter use COM port as logic interface. External control command is sent via RS-485 signal and connected with pin 3 and pin4 of COM port.



PIN	Network
1	CAN-H
2	CAN-L
3	RS485-A
4	RS485-B

Figure 6-5 Connection Diagram of COM Port

- (6) Firmware Version: REV001, software version: V000B000D001.
- (7) The Grid Disconnection Protection System according to C10/21 or C10/23 must be installed externally between the inverter output and grid connection point.
- (8) Stand-alone mode is not considered and evaluated in this report, the use of stand-alone mode and electrical installations for unit shall comply with national and local regulation.

## 1.3 Consideration of the foreseeable use

- Not applicable
- Covered through the applied standard
- Covered by the following comment
- Covered by attached risk analysis


## 1.4 Technical Data

Model:	KAC50DP
<b>PV input parameter</b>	
Maximum input voltage	1000 Vd.c.
MPPT voltage range	350~800 Vd.c.
MPPT voltage range (full load)	667~750 Vd.c.
Maximum input current	3*36 Ad.c.
PV I <sub>sc</sub>	3*40 Ad.c.
<b>Battery input/output parameter</b>	
Battery type	Lithium-ion
Input voltage range	350~750 Vd.c.
Maximum input/output voltage	750 Vd.c.
Maximum charging current	2*55 Ad.c.
Maximum charging power	55000 W
Maximum discharging current	2*55 Ad.c.
Maximum discharging power	55000 W
<b>Grid parameter</b>	
Rated input/output voltage	230/400 Va.c., 3/N/PE
Rated input/output frequency	50 Hz
Maximum input current	80 Aa.c.
Maximum input active power	50000 W
Maximum input apparent power	55000 VA
Maximum input active power from grid to battery	50000 W
Rated output current	72 Aa.c.
Maximum continuous output current	80 Aa.c.
Rated output active power	50000 W
Maximum output active power	50000 W
Maximum output apparent power	55000 VA
Maximum output active power from battery to grid (without PV input)	50000 W
Power factor	0.9 inductive(under-excited) to 0.9 capacitive(over-excited)

1.5 Label

<b>KSTAR</b>	
<b>Hybrid Inverter</b>	
Model:	KAC50DP
<b>PV input parameters</b>	
Maximum input voltage	1000 V d.c.
MPPT voltage range	350 V d.c. ~ 800 V d.c.
MPPT voltage range (full load)	667 V d.c. ~ 750 V d.c.
Maximum continuous PV input current	36/36/36 A d.c.
Maximum PV short circuit current	40/40/40 A d.c.
Maximum continuous PV input power	75 kW
<b>Battery input/output parameters</b>	
Battery type	Lithium-ion battery
Rated voltage	512 V d.c.
Battery voltage range	350 V d.c. ~ 750 V d.c.
Rated charging power	50 kW
Maximum charging current	55/55 A d.c.
Rated discharging power	50 kW
Maximum discharging current	55/55 A d.c.
<b>AC input parameters</b>	
Rated input voltage	230/400 V a.c., 3/N/PE
Rated input frequency	50 / 60 Hz
Maximum continuous input current	80 Aa.c.
Maximum input active power	50 kW
Maximum input apparent power	55 kVA
<b>AC output parameters</b>	
Rated output voltage	230/400 V a.c., 3/N/PE
Rated output frequency	50 / 60 Hz
Maximum continuous output current	80 Aa.c.
Maximum continuous output active power	50 kW
Maximum continuous output apparent power	55 kVA
Power factor	0.9 leading to 0.9 lagging
<b>General</b>	
Operating temperature range	-25 °C ~ 60 °C (Derating above 45 °C)
Protection class	I
Ingress protection	IP65
Operating altitude range	≤3000m
Production serial number	

Shenzhen Kstar New Energy Company Limited


Made in China

## 2. Order

### 2.1 Date of Purchase Order, Customer's Reference

2023-05-05

### 2.2 Test Sample(s)

- Reception date(s): 2023-05-05
- Location(s) of reception: TÜV SÜD Testing Center, D1 building, No. 63 Chuangqi Road, Shilou Town, Panyu District, Guangzhou 511447, P.R. China
- Condition of test sample(s): Intact

### 2.3 Testing

- Testing date(s): 2023-05-05 to 2023-06-25
- Location(s) of testing: TÜV SÜD Testing Center, D1 building, No. 63 Chuangqi Road, Shilou Town, Panyu District, Guangzhou 511447, China

### 2.4 Points of Non-Compliance or Exceptions of the Test Procedure

- None

## 3. Test Results

- "Decision rule according to IEC Guide 115:2021, clause 4.4.3, 4.5.1 was applied."

### 3.1 Positive Test Results

Test specification(s)	Report no. / Rev. No.	Date	Remark
Grid Code compliance	64.290.23.30804.01	2023-06-25	--

## 3.2 Points of Non-Compliance according to the test specification

- None

## 4. Test History

- None

## 5. Remarks

### 5.1 General

The user manual has been examined according to the minimum requirements described in the product standard. The manufacturer is responsible for the accuracy of further particulars as well as of the composition and layout.

### 5.2 Factory surveillance cycle

Your production facility is currently on the following surveillance cycle.

- Annual (12 month)
- Bi-Annual (6 month)
- Quarterly (3 month)
- None

## 6. Documentation

- None

## 7. Summary

The test specifications are met.



**TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch**  
**TÜV SÜD Group**

Tested by:

Yuneng Chen  
(Project Handler)

*Yuneng Chen*

*printed name, function & signature*

Approved by:

Kennen Wang  
(Designated Reviewer)

*Kennen Wang*

*printed name, function & signature*

