

GLV 005-03	Enphase Energy	Encharge Series	<h1>Synergrid</h1>
<b>C10/26 - DECLARATION OF CONFORMITY for power-generating units</b> GLV ed2.1.2 (12/2019)			
for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)			

The undersigned,	Manufacturer:	Enphase Energy Inc (USA)	Represented by:	David Minchin
	Address:	1420 North McDowell Boulevard Petaluma, CA, 94954 United States of America	Country:	Australia
			email:	dminchin@enphaseenergy.com
			Telephone:	(+61) 409567318

Hereby declares that each production unit completed in the list in tab 'list of power-generating units' of this homologation application complies with the following conditions:

1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).

2. In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.

2.1 For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.

2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available \* in the technical file:

- Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
- Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.

2.3 A list of the document references or the certificates of conformity referred to in the checklist Annex D is also available in the technical file.

**FINAL  
HOMOLOGATION**

*[Signature]*

Done at:	Melbourne, Australia		Homologated by Synergrid on:	18/08/2021
On:	3/09/2021		Stamp Synergrid & signature:	<b>SYNERGRID a.s.b.l.-v.z.w.</b> Galerie Ravensteingalerij 4/2 BE-1000 Bruxelles/Brussel T.V.A./B.T.W : BE 0402.958.091
(stamp manufacturer & signature)	<i>[Signature]</i> David Minchin ENPHASE ENERGY INC			

\* Transition period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019))

If at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports (exception 3), or that the units do not yet have all the required characteristics (exceptions 1 and 2), a **temporary homologation** may be granted. All necessary certificates and/or test reports must be in the possession of Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. If this is not the case, the temporary C10/26 homologation will be withdrawn.

POWER-GENERATING UNITS TO BE HOMOLOGATED FOR LIST C10/26 ACCORDING TO THE REQUIREMENTS OF ANNEX D OF THE TECHNICAL PRESCRIPTION C10/11 ed2.1 (01/09/2019)

C10/26 list with power-generating units in accordance with annex D of C10/11 ed2.1 (01/09/2019)

GLV 205-03 Enphase Energy Encharge Series

checklist ed 2.1.2 (12/2019)

1 SYNERGRID reference number (GLVxxx-yy-zzzz)	2 BRAND NAME	3 Name of the product SERIES	4 REFERENCE of the model / type of the unit	5 FIRMWARE VERSION	6 ONLY for units (suitable for) energy storage: Name and reference of the power control system		8 POWER			10 1-phase or 3-phase	11 ADDITIONAL CHARACTERISTICS					12 LIMITATIONS			13 APPLICATION		14 Synergriid approval date	15 Final homologation				
					power control system type EnFluRI	other power control system	P <sub>act,r</sub> rated (active) power (W)	S <sub>max</sub> maximum apparent power (VA)	D.3 integrated automatic separation system		D.3.1 "Type B ready" = suitable for use in installation ≥ 1 MW	D.4.1 additional operating frequency range (51,5 Hz - 52,5 Hz)	D.5.2 power response to underfrequency	D.7.2 active power reduction (PU)	0 certified power control system provided (e.g. EnFluRI)	D.7.1 only homologated for "small power-generating installations"	D.4.3 only homologated for connection to HV-network	D.5.1 only homologated for use in module < 500W	(-) only homologated as a backup power system according to §2.1.1	Wind energy			Solar energy	Other		
	Enphase	Encharge	ENCHARGE-3T-1P-INT	522-00002-01-V2.6.3882_rel/2 1.19 and higher	Envoys 5 metered		1280 W	1280 VA	1-phase	X	X	X	X	X				X								
	Enphase	Encharge	ENCHARGE-10T-1P-INT	522-00002-01-V2.6.3882_rel/2 1.19 and higher	Envoys 6 metered		3840 W	3840 VA	1-phase	X	X	X	X	X				X								

SYNERGRID a.s.b.l.-v.z.w.  
Galerie Ravensteingalerij 4/2  
BE-1000 Bruxelles/Brussel  
T.V.A./B.T.W. BE 0402.958.091

EXPLANATIONS FOR THE COMPLETION OF THE TABLE

Column	Title	Remarks
1	SYNERGRID reference number (GLVxxx-yy-zzzz)	In the case of a positive homologation, each C10/26-homologated power-generating unit is given a unique Synergriid reference number: xxx = unique reference of the manufacturer yy = serial number of manufacturer xxx's record xxx zzzz = unique unit reference for the manufacturer xxx <i>Note: "GLV" is the internal Synergriid-abbreviation for Declaration of Conformity, based on the Dutch word "Gelijkvormigheidsverklaring".</i>
2	Brand name	Brand name under which the unit is marketed on the Belgian market.
3	Name of the product series	Name of the product range. <i>Note:</i> For each separate product range (or each group of units with common characteristics) a separate checklist according to Appendix D is required (sheet 3) together with the corresponding conformity proof documents.
4	Reference of the model / type of the unit	Unique product name or reference. Units of the same product range must be unequivocally distinguished from each other through this name or reference.
5	Firmware version	Reference of the firmware version of the unit.
6	power control system type EnFluRI	This case is only applicable for units (suitable for) energy storage, provided with a power control system of type EnFluRI: Name and reference of the power control system of type EnFluRI, compliant to the requirements in C10/11 ed2.1 (01/09/2019) §4.1.7 and §7.11.2.1
7	other power control system	This case is only applicable for units (suitable for) energy storage, provided with a power control system of another type than EnFluRI: Name and reference of the power control system, compliant to the requirements in C10/11 ed2.1 (01/09/2019) §7.11.2.2
8	P <sub>act,r</sub> rated (active) power (W)	Active (electrical) power in W at the terminals of the unit, as stated on the technical sheet / data sheet / brochure and nameplate. (For photovoltaic inverters: see also definition in §3.2.5 of IEC 62894 2016-11)
9	S <sub>max</sub> - maximum apparent power (VA)	Maximum apparent (electrical) power at the terminals of the unit, as stated on the certificate / the test report / the technical sheet / data sheet / brochure.
10	1-phase or 3-phase	Indicate whether the unit is single- or three-phase. This characteristic refers to the unit itself, not to the nature of the connection to the distribution network to which the unit can be connected.
11	Additional characteristics	In these columns optional additional characteristics of the units are indicated, following the information in checklist annex D and the corresponding technical file. Put an "X" at each relevant additional characteristic. <i>Note:</i> Only units < 1 MW that are "type B ready" may be applied in an installation ≥ 1 MW (installation "type B" according to the European Network Code RIG). A unit < 1 MW is only "type B ready" if it complies with all optional properties ticked in column 1 of the checklist Annex D.

**FINAL HOMOLOGATION**